

# CONTRACTOR INFORMATION RE: GPRS REQUIREMENTS



New standards regarding service characteristics and meter communications came into effect on January 7, 2010. ENMAX Revenue Metering now requires customers to install a 3/4" conduit from the meter to the building exterior with a minimum 6" X 6" X 4" padlock-ready, (e.g. Hoffman cat. # A864CHQRFG (ABS) or cat. # ASE6X6X4 (metal, with an additional hasp)) weatherproof enclosure when the customer meets or exceeds the following service characteristics.

These enclosures are to be installed at a height no greater than 6 feet above finished grade and are available at local electrical suppliers.

Interval Meter Table	
Service Voltage	Disconnect Size
120/208 Volts	800 Amps
277/480 Volts	400 Amps
347/600 Volts	300 Amps

Please contact Revenue Metering for more information at (403) 514-3744.